

IEC**IECEE**

®

TM

Ref. Certif. No.

CN55203

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

SWITCH DISCONNECTOR FUSE

Name and address of the applicant

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Note: When more than one factory, please report on page 2

 Additional information on page 2

Ratings and principal characteristics

Uimp: 8kV;Ui: 800V;Ith: 200A(FUSERBLOC200A),250A(FUSERBLOC250A); Ue: AC690V;Ic: AC-22A:
200A(FUSERBLOC 200A); AC-23A: 160A(FUSERBLOC 200A); 250A(FUSERBLOC 250A) Utilization
category: AC-22A,AC-23A Number of poles:2P,3P,4P,3P+Additionalneutral pole(3 protected poles with an
uninterrupted neutral pole); Iq: 50kA;Rated frequency: 50/60Hz

Trademark / Brand (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

FUSERBLOC 200A, FUSERBLOC 250A;

Additional information (if necessary may also be reported on page 2)

IEC 60947-1:2020;IEC 60947-3:2020

A sample of the product was tested and found to be in conformity with

00901-CB2021CQC-099778

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.09,2021

Signature:

谢肇煦

Xie ZhaoXu

CB 0065327

IEC**IECEE**

®

TM

Ref. Certif. No.

CN55203

Name of the factory	Address of the factory
1.SOCIETE TIMELEC SARL	ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOCHANA NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS, Tunisia

Additional information (if necessary)

Date: Nov.09,2021

Signature:



Xie ZhaoXu