

# CERTIFICATE OF PRODUCT CERTIFICATION

## TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2011010306473391

Valid from: Oct.11,2022

Valid until: Jan.11,2031

**NAME AND REGISTERED ADDRESS OF THE APPLICANT** SOCOMEC China Co.,Ltd.  
Unit k, 6/F, No.258 , Fute North Road, Pilot Free Trade Zone Shanghai, P.R.China

**NAME AND REGISTERED ADDRESS OF THE MANUFACTURER** SOCOMEC S.A.S  
1, Rue De Westhouse 67230 Benfeld Cedex France

**NAME AND LOCATION OF THE FACTORY** BROYCE CONTROL LTD  
Pool Street. Wolverhampton, West Midland, WV2 4HN. ENGLAND

**PRODUCT NAME, MODEL AND SPECIFICATION** EARTH LEAKAGE PROTECTION RELAYS  
RESYS M40,RESYS N40;Un:AC690V;In:1000A;RESYS M40:Usn:DC12-125V,AC115/230V,AC400V;RESYS N40:Usn:AC/DC24-230V; Output contact:RESYS M40:Relay 1:AC-15:Ue/Ie:AC250V/2.5A;Relay 2:AC-15:Ue/Ie:AC250V/4A;RESYS N40:Relay 1,Relay 2:AC-15:Ue/Ie:AC250V/2.5A;RESYS M40:IΔn:30mA,100mA,300mA,500mA,1A,3A,5A,10A,30A(Adjustable);RESYS N40:IΔn:30mA,100mA,300mA,500mA,1A,3A,5A,10A,20A,30A(Adjustable);Rated Residual Operating Type:A,AC;Icw=IΔw:10kA.

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS** GB/T 22387-2016

**TYPE OF CERTIFICATION SCHEMES** Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Sep.21,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGN BY

郑士泉

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE