

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Transfer Switching Equipment

Name and address of the applicant

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

Note: When more than one factory, please report on page 2

SOCOMECELECTRIC (SHANGHAI) CO.,LTD
Building A30, No.5399 Waiqingsong Road Qing Pu.Shanghai
P.R.China☒Additional information on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

ATyS 500A,ATyS d 500A,ATyS t 500A,ATyS g 500A,ATyS p
500A,ATyS A 500A,ATyS C 500A, ATyS 630A,ATyS d 630A,ATyS t
630A,ATyS g 630A,ATyS p 630A,ATyS A 630A,ATyS C 630A;Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity withIEC 60947-6-1:2005 (2nd Edition) + AMD 1:2013 for use in
conjunction with IEC 60947-1:2007 (5th Edition) + AMD 1:2010As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2022CQC-103452


This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Jun.06,2023

Signature:


Xie ZhaoXu

CB 0073741

ATyS 500A,ATyS d 500A,ATyS t 500A,ATyS g 500A,ATyS p 500A,ATyS A 500A,ATyS C 500A,
ATyS 630A,ATyS d 630A,ATyS t 630A,ATyS g 630A,ATyS p 630A,ATyS A 630A,ATyS C 630A
Ui: 1000V(Main circuit), 300V(Control circuit);
Uimp: 12kV(Main circuit), 4kV(Control circuit);
Ue: AC415V;
ATyS 500A,ATyS d 500A,ATyS t 500A,ATyS g 500A,ATyS p 500A,ATyS A 500A,ATyS C 500A:
Ith: 500A;
Ie: 500A(AC-32B), 250A(AC-33B), 315A(AC-33B), 400A(AC-33B);
Icw: 10kA/60ms; Icm(Peak): 17kA; Iq: 50kA;
ATyS 630A,ATyS d 630A,ATyS t 630A,ATyS g 630A,ATyS p 630A,ATyS A 630A,ATyS C 630A:
Ith: 630A;
Ie: 630A(AC-31B), 500A(AC-32B), 400A(AC-33B);
Icw: 12.6kA/60ms; Icm(Peak): 25.2kA; Iq: 50kA;
Utilization Category: AC-31B, AC-32B, AC-33B,
PC Class;
ATSE,RTSE;
3P, 4P

Page 1 of 1

Additional information (if necessary)

Date: Jun.06,2023

Signature:

谢肇煦

Xie ZhaoXu

IEC

IECEE

®

TM

Ref. Certif. No.

CN59624

Name of the factory	Address of the factory
SOCIETE TIMELEC SARL	ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA NAASSEN 1135 NAASSEN GOUVERNORAT DE BEN AROUS, Tunisia
SOCOMEK S.A.S	1, Rue De Westhouse 67230 Benfeld Cedex France

Additional information (if necessary)

Date: Jun.06,2023

Signature:

谢肇煦

Xie ZhaoXu