

**IEC****IECEE**

®

™

Ref. Certif. No.

CN59619

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Transfer Switching Equipment

Name and address of the applicant

SOCOMECS.A.S  
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S  
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

Note: When more than one factory, please report on page 2

SOCOMECELECTRIC (SHANGHAI) CO.,LTD  
Building A30, No.5399 Waiqingsong Road Qing Pu.Shanghai  
P.R.China

Ratings and principal characteristics

Additional information on page 2

See the Appendix

Trademark / Brand (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

ATyS 800A,ATyS d 800A,ATyS t 800A,ATyS g 800A,ATyS p 800A,ATyS A 800A,ATyS C 800A, ATyS 1000A,ATyS d 1000A,ATyS t 1000A,ATyS g 1000A,ATyS p 1000A,ATyS A 1000A,ATyS C 1000A, ATyS 1250A,ATyS d 1250A,ATyS t 1250A,ATyS g 1250A,ATyS p 1250A,ATyS A 1250A,ATyS C 1250A;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-6-1:2005 (2nd Edition) + AMD 1:2013 for use in conjunction with IEC 60947-1:2007 (5th Edition) + AMD 1:2010

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2022CQC-103453

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jun.06,2023

Signature:

Xie ZhaoXu

**CB 0073740**



ATyS 800A,ATyS d 800A,ATys t 800A,ATyS g 800A,ATyS p 800A,ATyS A 800A,ATyS C 800A,  
ATyS 1000A,ATyS d 1000A,ATys t 1000A,ATyS g 1000A,ATyS p 1000A,ATyS A 1000A,ATyS C 1000A,  
ATyS 1250A,ATyS d 1250A,ATys t 1250A,ATyS g 1250A,ATyS p 1250A,ATyS A 1250A,ATyS C 1250A  
Ui: 1000V(Main circuit), 300V(Control circuit);  
Uimp: 12kV(Main circuit), 4kV(Control circuit);  
Ue: AC415V;  
ATyS 800A,ATyS d 800A,ATys t 800A,ATyS g 800A,ATyS p 800A,ATyS A 800A,ATyS C 800A:  
Ith: 800A;  
Ie:500A, 630A, 800A(AC-33B);  
Icw:20kA/60ms;Icm(Peak):40kA;  
ATyS 1000A,ATyS d 1000A,ATys t 1000A,ATyS g 1000A,ATyS p 1000A,ATyS A 1000A,ATyS C 1000A:  
Ith: 1000A;  
Ie:1000A(AC-33B);  
Icw:20kA/60ms;Icm(Peak):40kA;  
ATyS 1250A,ATyS d 1250A,ATys t 1250A,ATyS g 1250A,ATyS p 1250A,ATyS A 1250A,ATyS C 1250A:  
Ith:1250A;  
Ie: 1000A(AC-33B);1250A(AC-32B);  
Icw:25kA/60ms;Icm(Peak):52.5kA;  
PC Class;  
ATSE,RTSE;  
3P,4P

Page 1 of 1

Additional information (if necessary)

Date: Jun.06,2023

Signature:

谢肇煦

Xie ZhaoXu



**IEC****IECEE**

®

™

Ref. Certif. No.

CN59619

**Name of the factory****Address of the factory**

SOCOMEK S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Additional information (if necessary)

Date: Jun.06,2023

Signature:



Xie ZhaoXu