



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC20107279482

Type II CQC Certification

NAME AND ADDRESS OF THE APPLICANT

SOCOMEK S.A

1, Rue De Westhouse 67230 Benfeld Cedex France

NAME AND ADDRESS OF THE MANUFACTURER

SOCOMEK S.A

1, Rue De Westhouse 67230 Benfeld Cedex France

NAME AND ADDRESS OF THE FACTORY

SOCOMEK S.A (V005810)

1, Rue de Westhouse 67230 BENFELD CEDEX FRANCE

PRODUCT NAME, MODEL AND SPECIFICATION

Fuse-switch-disconnector

FUSERBLOC 315A, FUSERBLOC 400A; (Uimp):8kV; (Ui):800V; (Ith): 315A(FUSERBLOC 315A),400A(FUSERBLOC 400A); (Ue)/(Ie): AC-22B:AC690V/400A(FUSERBLOC 400A); AC-23A:AC690V/315A(FUSERBLOC 315A); (Iq):50kA; AC-22B,AC-23A; 2P,3P,4P,3P+Additional neutral pole; 50/60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.3-2017

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020 .

Valid from: Dec.29,2020

Valid until: Dec.29,2025

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0412252